



Government Of West Bengal
Office Of The Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services
6, Diamond Harbour Road, Silpara, Kol-700008

Memo no.: IND/WB/FES/20192020/55406

Date: 09-06-2023

From:

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

To: Parameswar Mahavidyalaya B.Ed (M.Ed) 19/5/15.
Vill. P.O.-Namkhana, P.S.-Namkhana, Dist.-South 24 Parganas, Pin-743357

Sub: Fire Safety Certificate for a G+II storied under group Educational Building at the premises No.-Vill.+P.O.-
Namkhana, P.S.-Namkhana, Dist.-South 24 Parganas, Pin-743357.

This is in reference to your application no. 0125189231200117-dated 31-05-2023 regarding the Fire Safety Certificate for a
G+II storied under group Educational Building at the premises No.-Vill.+P.O.-Namkhana, P.S.-Namkhana, Dist.-South 24
Parganas, Pin-743357.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found
satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the
aforesaid building.

Recommendation:

1. All the Fire Safety Recommendation which was issued from this department vide memo no. IND/WB/FES/20192020/55406 dated 09.07.2019 to be followed strictly at all time.
2. Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the driveway.
3. The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.
4. To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.
5. Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.
6. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
7. The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and testing.
8. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Electrical switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher confirming I.S. specification.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189231200117

Page : 1

10. First aid Firefighting system shall be provided as per I.S. specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Firefighting installation in the building to keep them in perfectly good working condition at all the times.
12. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.
13. Periodical flashing of water from the fire water pipe line shall be made to maintain efficient working performance of above mentioned system.
14. This Fire Safety Certificate is valid for 03(Three) years and have to be renewed after three years from the date of issue of this certificate .
15. Renewal of Fire Safety Certificate is to be obtained from the Divisional Fire Officer, West Bengal Fire & Emergency Services, for performances of all the Life and Fire Safety arrangements and installation of the building

Signature valid

Digitally signed by TAJRIN
KUMAR D...
Date: 2023.08.15 03:37 IST

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/2019202155406